

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No.F.6/DFS/MS/School/2022/SZ/174

Dated: 15/02/2022

FIRE SAFETY CERTIFICATE

Certified that the Guru Nanak Khalsa Girls Sr. Secondary School located at Sadar Bazar, Delhi Cantt, New Delhi-110010, comprised of Ground & Three Upper Floors owned / occupied by Gurudwara Committee has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2018/SZ/2299 dated 28/09/2018. The premises was re-inspected by the officer concerned of Fire Service on 31.01.2022 in the presence of Smt. Anita Ahuja (Vice-Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Education-I" (Group-B) with effect from 15/02/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 15/02/2022 at New Delhi by.


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. The Principal, Guru Nanak Khalsa Girls Sr. Secondary School, Sadar Bazar, Delhi Cantt, New Delhi-110010. (ID-1720086)
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is, available on WWW.dfs.Delhigovt.nic.in.